

## NOTES:

1. FACE OF PANEL AT CLOSURE POUR SHALL HAVE EXPOSED AGGREGATE FINISH.
2. METHOD OF FORMING CLOSURE POUR TO BE DETERMINED BY THE CONTRACTOR. THE FORMS SHALL BE REMOVABLE AND SUPPORTS SHOULD NOT PENETRATE THROUGH TOP OF POUR UNLESS APPROVED BY THE ENGINEER.
3. AT THE CONTRACTOR'S OPTION, GALVANIZED INSERTS MAY BE CAST INTO THE BEAMS TO FACILITATE FORMING OF THE CLOSURE POUR. THE INSERTS SHALL BE SHOWN ON THE SHOP DRAWINGS AND MAY NOT BE CLOSER THAN 2'-0" O.C.. CALCULATIONS SHALL BE PROVIDED ALONG WITH MANUFACTURER'S RECOMMENDATIONS DEMONSTRATING THAT THE INSERTS ARE SUFFICIENT FOR THE INTENDED PURPOSE.
4. CLOSURE POUR CONCRETE SHALL HAVE A MINIMUM 28 DAY COMPRESSIVE STRENGTH OF XXXX PSI AND SHALL REACH A COMPRESSIVE STRENGTH OF XXXX PSI BEFORE THE ROADWAY IS REOPENED TO PUBLIC TRAFFIC.

*(Modify note as required to meet the construction requirements of the project. At a minimum, the 28 day compressive strength shall be 4000 psi.)*



LRFD BRIDGE  
MANUAL, PART III

# CLOSURE POUR CONSTRUCTION NOTES

CLOSURE POURS

DATE OF ISSUE  
APRIL 2024

DRAWING NUMBER  
**7.6.7**