



1. COLLARS TO BE 4000 PSI CEMENT CONCRETE MASONRY REGULAR OR H.E.S AS DIRECTED.( SEE MASSDOT SPECIFICATIONS FOR DESIGN REQUIREMENTS).

**NOTES:**

1. STANDARD PARALLEL BAR GRATES TO BE USED SEE DETAILS ON DRAWINGS 206.0.1
2. MINIMUM C.I FRAME MASS -205 LBS. EACH
3. FOR DESCRIPTIONS, MATERIALS AND CONSTRUCTION METHODS SEE LATEST STANDARD SPECIFICATIONS

**TYPE "A"**

4. 4000 PSI CEMENT CONCRETE ( SEE MASSDOT SPECIFICATIONS FOR DESIGN REQUIREMENTS)

**TYPE "B"**

5. NOMINAL CONCRETE BLOCK DIMENSIONS  
HEIGHT: 4" TO 8"  
WIDTH: 8"  
LENGTH: 8" TO 16"
7. BLOCKS TO BE SET IN FULL BED OF MORTAR
8. THIS DROP INLET IS TO BE USED AT ANY LOCATION WHERE IT MAY PRESENT A HAZARD TO VEHICLES THAT RUN OFF THE ROAD. FOR FLUSH SEE DRAWING 206.1.1